

@IRIS[™]

Integrated Renewable Energy Inversion System



Table of Content

A. Product Overview	4
Main components:	4
B. Technical Highlights	5
1. APPLICABLE STANDARDS	5
2. SCOPE OF WORKS	5
3. HARDWARE SOLUTION	5
4. SOFTWARE SOLUTION	6
4.1. Support protocol	6
4.2. System sizing	6
4.3. Software structure	6
4.4. Software Functions	7
4.4.1. Data Acquisition (DA)	7
4.4.2. Real-time Database (RTDB) Processing	8
4.4.3. PV power plant control (PPC)	8
4.4.4. Historical Information System (HIS)	9
4.4.5. Human-Machine Interface (HMI)	10
4.4.6. Solar generation forecast	15
4.4.7. Fault diagnosis	15



A. Product Overview

@IRIS is the Integrated Renewable Energy Inversion System which is designed and provided by ATS including hardware as well as software modules.

Currently, fossil energy types such as coal, oil, etc. are running out, and the problem of environmental pollution caused by CO2 emission is getting worse. Modern society need to find clean, environmentally friendly energy sources, in which renewable energy sources such as solar and wind energy are one of the alternative choises of energy in the future.

The renewable energy inversion systems are increasing strongly, along with the continuous improvement in manufacture technology and the redution of investment costs, have been increasing market share, as well as increasing the importance in electricity system of each country to meet the energy demand.

An overview of inversion process of PV solar energy to electrical energy is shown in the figure 1.

Photovoltaic modules will convert solar radiation energy into DC electricity by photoelectric effect. This DC power will be converted into AC power with reference frequency according to the frequency of the grid through the DC/AC energy converter (Inverter). The step-up voltage transformers and transmission lines will connect and synchronize energy to the national grid.

Connection structure, data acquisition for supervisory control of @ IRIS system is shown in the figure 2.

MAIN COMPONENTS:

- Supervisory Control And Data Acquisition system (SCADA) plays an extremely important role in ensuring stable operation of the system, optimizing plant performance, minimizing risks and highest reliability. The main functions of software system include:
 - * Communicate with devices in the system to collect data (electrical data, weather data, hardware device status data);
 - * Monitoring plant status in real-time;
 - Monitoring operation status, event and alarm, support tool for maintenance;
 - * Provides intuitive tools for displaying working data;
 - * Directly control the power generation of the system when receiving commands from the central control room on the basis of online feedback signals (active power control, reactive power control, frequency and voltage stability control, ramp rate control, reactive power compensation (if any), start, shutdown sequence control);
 - * Connect with SCADA/EMS system in the dispatch centers for the operation of the power grid;
 - Plant generation prediction;
 - * Plant analysis and failure detection;
 - * Support services to remote repair and operation.
- Hardware devices supporting power invertion: including power electronic devices with the function of converting DC current into AC current to connect to the power grid.



Figure 1. Process of transforming renewable energy into electricity

Figure 2. Principle of Integrated Renewable Energy Inversion System

1. APPLICABLE STANDARDS

@IRIS system is designed to ensure compliance with Vietnamese and international technical standards such as IS/IEC/IEEE with the latest version; policies, regulations and orientations for renewable power development in Vietnam; construction standards and national grid code.

@IRIS system are based on the design with high tolerance, redundancy configuration of critical devices in the system, to providing an optimal, safe and stable power inversion system with long-term economic efficiency.

With a solution based on computerized platform and logic software architecture complying with IEC 61131-3 standard, our central control and monitoring system can meet requirements according to technical agreements, requirements grid connection techniques, as well as regulations and rules of the Vietnamese government and authorities.

2. SCOPE OF WORKS

@IRIS will assist operators to perform all supervisory and control functions. All important information about the operation of the plant including system characteristics, measurement data, status of integrated controllers, sequence control functions, alarm functions ... will be collected and displayed immediately on the control operating interface.

We propose completed implementation range including design, production, construction and installation, testing, commissioning and adjustment of Integrated Renewable Energy Inversion System, provision of COD-Ready services to ensure to meet, comply with technical requirements and specialized standards and energizing successful system into national power grid. Basic scope includes:

- Designing an integrated renewable energy inversion system.
- Provision and installation of Hardware equipment system at power plant: Inverter, Weather station, LAN equipment, port and I/O converter, computerized system, peripheral equipment and other auxiliary systems.
- Provision and installation of Integrated Software System to supervisory and control the energy inversion system.
- Testting, commissioning and related agreements and approvals (COD-ready services) to energize the system into national power grid successfully.
- Training, operating instructions and maintenance services.
- All provided equipment and software are warranted within 24 months from the date of installation with 24/7 technical support and troubleshooting within 24- 48 hours.

3. HARDWARE SOLUTION

The system is built with the following main hardware components:

- Inverter: perform the function of converting DC energy from photovoltaic panels into AC energy and equipped with monitoring and control capabilities through industrial protocols.
- Communication and Controller Unit at each integrated inverter station with digital and analog inputs/outputs and support protocol converter function (Modbus RTU/TCP) to collect all monitoring and control data of PV solar energy inversion system such as DC combiner box, inverter, multi-function meter, MV transformers, MV switchgear and other auxiliary systems (AC/DC distribution system, fire alarm system, etc). All collected data will be connected to the centralized monitoring and control system through high-speed fiber optic ring network.



Figure 3. Hardware architecture of @IRIS

- Weather station at the central locations of the generation area will measure solar radiation intensity, ambient temperature, PV panel temperature, wind speed and direction, humidity, pressure, for analyzing the power generation efficiency of the plant as well as planning the operation.
- Equipment at the central control room:
 - * Power Plant Control and @IRIS Server: operate in redundant mode, to collecting all data, processing, calculation and displaying on user interface, and perform monitoring, control functions of the energy inversion system. These server are designed based on industry standards, with open architecture, providing network connectivity and compatibility with widely used industrial protocols, ensuring any damage to the device does not affect the process of monitoring and operating the PV plant. This servers also act as Gateway, to connecting and exchanging SCADA data with Control Centers through Gateway computer at integrated substation control system.
 - Operation Workstation: provides Human-Machine Interface (HMI), allow operator to interactive and implement monitoring and control of the system.
 - * HIS and Engineering computer: for long term data storage and historical data mining applications for analysis, review and report, engineering applications for database configuration, building interfaces, and maintaining SCADA systems.
 - * Network Switch devices: establish and manage optical cable ring network that assures the continuous operation of the system in case of any single failures of LAN parts. All data for monitoring and control of energy inversion system will be connected, collected and shared on the central control and monitoring system based on the High-speed fiber optic ring network.
 - * GPS-Synchronized network clock to device time synchronization in the system..

4. SOFTWARE SOLUTION 4.1. Support protocol

The system provides support for standards-based protocols widely used in industry such as:

- Modbus Serial/TCP (combiner box, Inverter, weather station, data concentrator, multi-meter, protection relay...).
- IEC61850, SEL FastMessage, DNP3,... (Protection relays, power quality monitoring equipment,...)
- IEC 62056/IEC61107 (Tariff meter)
- And other protocols are widely used in industries...

4.2. System sizing

@IRIS system provided by ATS ensures ensures that the performance met all requirements of current system and extended in the future without having to upgrade any of the control system components.

The @IRIS system can support sizing capacity for over 2,000 IEDs, controller and monitor, and 256,000 data points.

4.3. Software structure

@IRIS software system is designed with modular-architecture to easily manage, maintain, upgrade, ensure security and stability.

The main software modules of the @IRIS system include:

- Data Acquisition module (DA)
- Real-time Database (RTDB)
- PV Power Plant Control
- Historical Information System (HIS)
- Human Machine Interface module (HMI)
- PV power plant generation predicting module
- PV power plant analysis and failure detection module

@IRIS

Figure 4. Software Architecture of



Centralized data acquisition, supervisory and control system

4.4. Software Functions 4.4.1. Data Acquisition (DA)

The Data Acquisition module will perform initializing, managing real-time information channels and communicating data with monitoring and control devices and other systems. This is an integral part of any data acquisition, data processing and control system.

The Data Acquisition module will acquire all available analog data, status data and perform control signal from PV energy inversion system through DC string combiner boxes, Inverter controllers, Inverter station comunication and controller units, relays, Common IO devices, Weather station, Multi-function meters, MV switchgear.

DA module process following data types:

- Analog data
- Status indications and alarm signal
- Time stamped status and SOE
- Manually entered data
- Oscillograph information
- Disturbance and Power Quality Information
- Control command...

Data acquisition from main PV power plant devices:

- DC string combiner boxes
 - * Current, voltage, power of each input PV string;
 - * Output current, voltage and power of DC combiner box;
 - * Status, alarm signal of output MCB of DC combiner box;
 - * Protection signal;
 - * Box temperature (if any).
- Inverters:
 - Analog Signals:
 - DC current, voltage, power of each input;

🗙 ATS SmartIO Administrator								-		×
<u>F</u> ile Edit View Logs H	lelp									
⊟ Gateway	^	Name	Da	ata type	Value	Quality	Timestamp			Descript ^
A0 (IEC101 Slave) (Enabled) A1 (IEC101 Slave) (Enabled)		P1	Bo	ol	True	Good	25/07/2016	07:59:55.6	8	P1BYA0
Enabled)		P2	Bo	ol	False	Good	25/07/2016	08:00:02.0	6	P1BYA0
A138		P3	Bo	ol	True	Good	25/07/2016	08:00:54.4	7	P1BYA0
Single point inform	nation	P4	Bo	ol	True	Good	25/07/2016	08:01:00.1	7	P2BYA0
Double point infor	matior	P5	Bo	ol	False	Good	25/07/2016	08:01:06.2	8	P2BYA0
Measured value, s	short f	P6	Bo	ol	True	Good	25/07/2016	08:01:11.6	3	P2BYA0 ~
··· Controller (Heartbeat channel)	(Enat	<								>
DCS (Modbus slave channel) Dow1	(Enab	Туре		Point1/S	ource	Point2/De	est	Direction	/Tim	er
T1 - Coil		Upon chano	e	DCS Det	v1 T1 P2	A0 S1 A1	SPI P15002	Point 1To	2	
T2 - Discrete innut	~	Upon chang	e	DCS.De	v1.T1.P2	A1.S138.	A138.SPI.P	Point1To	2	
<	>									
Time	Source		Co	ntent						^
25/07/2016 08:01:19.2	DCS.Dev	1	>>	[127.0	.0.1:65200	6]: Tranl	[d(0x00 3A)	, Devid	(1)	, Fc(1,
25/07/2016 08:01:19.2	DCS.Dev	1	<<	[127.0	.0.1:65200	6]: Tranl	[d(0x00 3A)	, Devid	(1)	, Fc(1,
25/07/2016 08:01:19.2	DCS		<<	[127.0	.0.1:65200	6]: 00 3 7	00 00 00	04 01 0	1 0	1 2D
										~
<										>
Server 127.0.0.1:8500 Ready										

Figure 5. Data Acquisition interface

- Output AC phase-phase, phase-earth voltage, current, active power, reactive power, apparent power, power factor, frequency;
- Inverter efficiency;
- Harmonic distortion;
- Daily power yields, total power yields;
- Total daily operation time;
- Internal temperature;
- ...
- Status signals:
- Operation Status: Run, Stop, Initial Standby, Emergency Stop...
- Alarm state signal: Communication fault, Low Insulation resistance, Insulation plate abnormal, fault, derating run, alarm run
- Fault state: DC under-voltage, DC over-voltage, AC under-voltage, AC over-voltage, Under-frequency, Island protection, Over-temperature, Overload protection, Earth Fault protection, AC switch abnormal, DC switch abnormal...
- Device status signal: AC switch state, DC switch state, DC fuse state...
- MV transformer:
 - Protection Signals.
 - Oil/Winding temperature alarm
 - Oil/Winding temperature trip
 - Pressure relief trip (if any)
 - Low oil level signal (if any)
 - Gas relay alarm (if any)
 - Gas relay trip (if any)
 - Supervision Signals:
 - Tap changer position (if any)
 - Operation temperature (winding, oil)
- MV Switchgear:
 - Voltage, current, active power, reactive power, frequency, power factor...
 - * Status and alarm signal of circuit breaker, load break switch.
 - * Relay protection signals
- Meteorological station:
 - * Global horizontal irradiance (GHI);
 - Plane of the array irradiance (POA);
 - Ambient temperature;
 - * PV Panel temperature;
 - Wind direction and wind speed;
 - Humidity
- * Atmospheric pressure...

4.4.2. Real-time Database (RTDB) Processing

The Real-time Database module is a central component in the system. RTDB is a data bridge between the Data Acquisition module and other application modules (HMI, HIS, etc.), which manages and processes all real-time data of the system.

Real-time database management with ability to process unlimited data points, collecting data from operation level or processing level, commonly from IEDs such as relays, BCUs, IO device, inverter controller, sensor... Data will be processed and converted to archiving form and allow to covert depend on user requirements.

Technical specifications of RTDB:

- Designed with Client/Server model.
- Other application can access each data point in real-time database.
- Support multi session access to real-time database at the same time.
- Process and convert to appropriate data format as requirement of other applications.
- Ensure the integrity and reliability of the electrical system data.
- Automatically send and receive data as requirement of other application.
- Support import/export function to facilitate of data management processing.
- Support mathematic and logic functions used to calculate.

RTDB supports the following types of data processing:

- Quality Data
- Analog Data
- Status Data
- Calculated Data
- Sequence Of Event Data
- Manual input data
- Command Data, etc



Figure 6. Power plant control function block diagram

4.4.3. PV power plant control (PPC)

PV Power Plant Controller (PPC) is an intelligent vendor-independent system for dynamic PV power plant control and grid code compliance, customizable to satisfy any grid requirement while ensuring interoperability with plant SCADA systems.

Our solution is suitable for controlling PV Power Plant with different Inverter vendors (such as ABB, SMA, Huawei, TMEIC, Sungrow, etc.). The PV plant controller will be implemented at plant-level logic and utilized closed-loop control schemes. Real-time commands will be sent to each inverter via industrial protocols such as Modbus RTU, DNP3, IEC 61850, IEC 60870-5-104, etc... to achieve fast and reliable regulation of PV power plant generation.

The main PV power plant control functions:

- Active Power Control: Hold the output at fixed commanded Setpoint or react to curtailment commands by operator and the Load dispatching center. Ensure that output of PV power plant does not exceed specified limit.
- Ramp rate control: Limit a smooth active power ramp rate must be followed in the output to the grid, ensure not to cause to the system instability at the grid connection point.
- Reactive Power Control: Used to hold the plant at a specific reactive power output.
- Power Factor Control: Allow the plant to maintain a desirable power factor at the point of connection.
- Grid support control:
 - * AGC-Automatic Generation Control: Automatic regulate the active power delivered based on the instantaneous frequency deviation of the Grid.
 - AVR- Automatic Voltage Regulator: Allows the plant to dynamically provide reactive power support, based on system voltage.
 - * Fault Ride-through capability: do not trip off during system disturbances such as specific low and high voltages or lowand high-frequency circumstances and continue to provide power when the grid needs it.
- Power plant start-up/shutdown:
 - If a planned outage is needed, operations should have a way to take the plant offline in a controlled manner by one click activity. Similarly, after the outage period; the plant needs to come up smoothly.
 - * When a shutdown request is provided along with required confirmation, the active power of plant will ramp generation down all the way to OMW. Inverters will then be stopped. Likewise, when a startup command is issued, each inverter will be started and ramped up to the plant level setpoint.
 - * Operator can configure automatic start-up power plant at setting time or at the beginning of solar radiation intensity of shutdown power plant at the end of solar radiation intensity.
- MV switchgear control function:
 - * Remote control of MV switchgear at each Inverter stations with Interlocking Logic via Relays and Bay Control Units in specific conditions such as maintenance and repair process or in fault isolating and recovering process.

4.4.4. Historical Information System (HIS)

The Smart Historical Information System (SmartHIS) is the historical repository of all the information related to the Microgrid system which is time-series generated under normal operating conditions and/or during disturbances. The SmartHIS implementation will be predicated on the client-server architecture to collect, process, store, manage and retrieve data.

With SmartHIS the operators can store and maintain real-time data from any system point. The data will be stored in its exact resolution for a long period of time.

Multiple access security levels will be provided with firewalls, users ID and passwords. It must come with proxy server and IP masking capability to prevent unauthorized IP access to the server. Security for data access and point configuration is defined for read only; write only, both or none.

(1). Benefit

 Massive scalability and performance: the database can be scaled to support millions of devices or time series data points in continuous flow and perform real-time analysis.

- Reduced downtime: In scenarios where downtime is unacceptable, the architecture of a database that is built for time series data ensures that data is always available even in the event of network partitions or hardware failures.
- Lower costs: High resiliency translates into fewer resources needed to manage outages. Fast and easy scaling using commodity hardware reduces the operational and hardware costs of scaling up or down.
- Improved business decisions: customers can analyze data in real time and make faster and more accurate adjustments for energy consumption, device maintenance, infrastructure changes, or other important decisions that impact the business

(2). HIS applications

a)Report

Reports can be built using Data Link tool (an add-in for Microsoft Excel). This add-in can allow data to be retrieved directly from within the spreadsheet program. User can create complex reports and graphs using current or historical data from the HIS.

b) Web-based monitoring subsystem

The Microgrid control system supports to display data at utility office for remote monitoring. It is able to display in web service or mobile application with integration open source web server.



4.4.5. Human-Machine Interface (HMI)

- The HMI is connection interface between the user and the monitoring, controlling program of the central control system, as well as other applications. HMI allow to monitoring, controlling all primary device in power plan, access to storage data simply and friendly.
- The design of Screen can be simply modified and reused.
- User Interface can immediately reflect by light and sound indication corresponding with happening event of operator or primary devices.
- The operator can implement every controlling action exclude automatic controlling functions. All message or warning signals will be unlimited follow time sequence. All signals of operation process will be collected and continuously warn to operator at Alarm screen.

At the central control room, the HMI interface system will be built integrated and unified, support the operator to be able to perform all monitoring and control operations of the solar inversion system.

The main functions include:

(1). Manage system access

- Manage Username and password with an unlimited number of access accounts.
- Manage access levels corresponding to each Username.
- Assign Username for all operations after access.
- Add new users, edit or delete existing users with system administrator level.

(2). Monitoring

The HMI function is designed with multi-layer architect, more lower layer more detail information:



Figure 9. Power Plant Dashboard

Display plant dashboard with current generation parameters (3 phase currents, voltage, active power, reactive power, power factor and frequency); total plant daily, weekly and monthly yield; current weather parameters...



Figure 10. PV power plant Single Line Diagram

Display solar energy inversion system oneline diagram with main devices and operation parameters include DC SCBs, Inverters, MV transformers, MV switchgear,...

Inverter Station B

B. Technical Highlights

Figure 11. Inverter Station Screen

Display operation parameters, status signal, alarm and protection signal of each Inverter station.



29 🛛 🐻 🖶

485 kV

20 kVAR

Set Point Values

Out AC Power

Out Re. Power

Over Heating

UDC High Limit

Month

Out Power Factor 0.

Ramp Rate Control

Phase Loss

Spare

Yea

Display analog parameter such as input current, input voltage, output current, output voltage, output power, power factor, frequency, operation time; status, alarm, protection signal of input and output switching devices of each Inverters...

Figure 13. MV transformer monitoring

Display operation signal of tie-transformer such as tap position, temperature, alarm and protection signal...

11





🦔 DAMI SOLAR PLANT - MONITORING AND CONTROL SYSTEM 🛛 💽 🛛 Admi

485 kW

Ground Fault

🥥 DC Brk Trip

Day

In DC Current

In DC Voltage

In DC Power

Efficiency

Over Voltage

O/U Frequency

Realtime Values 728.00 A

Out Current

Out Voltage

Out Frequency

Alarms

Grid Outage

🥥 AC Brk Trip

Week

Out Power

520.00 V

485 kW

185 kVAR

Energy Production





🚗 🚭 🛛 DataServer 🚍

MPPT Mode

400

 \approx

Home

9

Plant Plant Power Monitor

Alarm

XX Utilities

🔨 🖉 PPC 🖾 PMS

Mode

AC CB

OperatingTime

Today Trend

Running

15 hours

Emergency

Inverter (INV)



Figure 14. PV String Monitoring

Display all analog parameter such as: current, voltage and power of each solar string, surface temperature and evaluate efficiency and operation time of each PV string



Figure 15. Weather conditions Monitoring

Display current value of weather conditions such as solar radiation, ambient temperature, atmospheric pressure, wind direction and speed, humidity, ...



Figure 16. Power Quality Monitoring

Monitor VSSI – Voltage sag, well and interrupt, harmonic distortion, voltage fluctuation, frequency variation, power factor,...

(3). Supervisory control

F

Âlarm

frend

The supervisory control commands shall be enterable at the Operator's request, via tabular and graphic displays, will be processed by the Power plant controller and sent to the Inverter controller, relay, BCU only after the command has been validated. The control sequence shall be predicated on the "select and check before operate (SBO)" philosophy in order to ensure the operation security.

The supervisory control step sequence is provided as follows:

- Display schematic diagram or tabular display on displays. ٠
- Select the device for remote control by means of cursor position-٠ ing.
- Invalid requests shall result in a message showing the reason for ٠ rejection and the cancellation of the point selection - the ability shall be provided for the Operator to insist on the request in case of predefined non-critical situations.
- Change the color and blinking attribute of the affected device or ٠ function on the schematic diagram if the operation has been performed.

a) PV power plant control functions:

- Dynamic voltage and/or power factor, reactive power regulation of the solar plant at the point of interconnection (POI) to Grid support.
- Active power output control with fixed setpoint or curtailment command of the solar plant when required so that it does not exceed an operator specified limit.
- Frequency control to lower plant output in case of over-frequency situation or increase plant output (if possible) in case of under-frequency.
- Support incorporate fault ride-through capability is that they do not trip off during system disturbances such as over - under voltage, over - under frequency but continue to provide power when the grid needs it.
- Start-up and shut-down control of whole power plant.

a) MV switchgear control functions:

Device Control - The capability to control devices shall be enabled in accordance with the pre-defined areas of responsibility; control commands entered by non-authorized users shall be inhibited.



Figure 17. Power plant control user interface



Figure 18. MV Switchgear Control

(4). Alarm processing

The monitoring of alarms coming from the equipment operation has a major importance in the power plant operation, especially during significant events such as total or partial system outages. An event is defined as any change in the power plant operation. An alarm is a subgroup of events. Any unsolicited status change or violation of any allowable limits of the power system variables shall initiate an alarm.

As a minimum, the following information shall be included for each alarm:

- Date and Time
- Substation Name
- Element Identifier
- A brief description of the alarm condition

(5). Trending

The PV plant mornitoring and control system shall incorporate trending functionality. It shall be possible to represent trends both from historical data, using the information stored in the HIS, and with real-time data.

There are some trend types the system can support:

- Electrical parameters trending (U, I, P, Q, Hz, PF...)
- Temperature trending (Ambient temperature, Room temperature, PV panel temperature, Inverter temperature, Tie transformer temperature...)
- Auxiliary parameters trending...

(6). Tagging

Tagging of the circuit breakers and disconnector switches, inverters... for maintenance, hot line work or automatic re-closing is an important part of the SCADA system design criteria. This will be accomplished by using as one input in interlock condition.

The Tagging function also allows the user to enter the following tag information:

window

Figure 19. Alarm presentation

- Job/Permit Number
- Date
- Purpose
- "Tagged by" and "Tagged for" Information

		P.S SUB	METER	DISPLAY	DISPLAY	MONITOR	UTILITIES	LOG OFF	Operator: ad	min	CONNECTED	AUDIBLE] 🗶 📋	7/ 9/ 13	11:28:4
		A	LARM SUMM	ARY						· · · · · · · · · · · · · · · · · · ·	ALARM HISTOP	RY			
Alarm Level															
Date	Time	Alam Comment	Value	Linit	Type	Group	State +	Historical Alarn	n			FROM: 05:25:2	1 PM 09/03/20	13 TO: 05:25:21	PM 09/04/2013
07 Sep	11:27:17	admin Log On	On	off	ON	System.Template	UhAdk 🗐	Date	Time	Alam Comment	Value	Linit	Type	Group	State A
07 Sep	11:26:30	Subs_CTL_Loc	Remote	Remote	OFF	System E33.Subs	UnAdk	03 Sep	17:54:46	NHTTNT_Subs_CTL_Loc	Remote	0	OFF	H_TT_NHA_TRANG.:	UnAdk
07 Sep	11:26:06	KHWNSHD_Subs_CTL_Loc	Remote	Remote	OFF	stem.KH_WKHD.Sul	UNAdk	03 Sep	17:54:47	NHTTNT_Subs_CTL_Loc	Local	0.000000	NORMAL	HUTUNHAUTRANG.:	UnAck RTN
07 Sep	11:26:05	KHNMS_Subs_CTL_Loc	Remote	Remote	OFF	ystem JOI_JANS.Subr	UNAdk	03 Sep	20:26:21	HITTNT_Subs_CTL_Loc	Remote	0	OFF	HUTUNHAUTRANG.:	UnAdk
07 Sep	11:26:05	KHSDAU_Subs_CTL_Loc	Remote	Remote	OFF	/sten.KH_SDAU.Sub	UNAdk	03 Sep	20:27:36	HITTIT_Subs_CTL_Loc	Local	0.000000	NORMAL	HUTUNHAUTRANG:	UnAck RTN
07 Sep	11:26:05	KHNHOA, Subis_CTL, Loc	Remote	Remote	OFF	sten J21_NHOA.Sub	UnAck	03 Sep	20:29:11	HITTNE Subs_CTL Loc	Remote	0	OFF	HUTUNHAUTRANG.:	UnAdk
07.5en	11:26:05	KHOCK Side CTL Inc.	Renote	Remote	OPP	Internation RDCR.54	Unärk T	03 Sep	20:29:25	HHTTNT_Subit_CTL_Loc	Local	0.000000	NORMAL	HUTUNHA TRANS.	UnAck RTN
4							,	03 Sep	20:31:32	HITTIT Subs_CTL Loc	Remote	0	OPP	HUTUNHAUTRANG.:	UnAdk
								03 Sep	20:32:13	HHTTHT_Subs_CTL_Loc	Local	0.000000	NORMAL	H_TT_NHA_TRANG.:	UnAck RTN
Alarm Level	2		_		_			03 Sep	20:32:35	HHTTHE SUBAL CTL LOS	Remote	0	OPP	HUTUNHAUTRANG!	UnAdk
Date	Tine	Alam Comment	Value	Linit	Туре	Group	State ^	03 Sep	20:32:45	HHTTHT_Subs_CTL_Loc	Local	0.000000	NORMAL	H_TT_NHA_TRANG.:	UnAck RTN
07 Sep	11:26:28	MM0U1_Amax (BAY-301)	0.673	5.000	LD	stam JOL_NENH_THL	UnAdk	03 Sep	20:33:05	HHTTHE Subsciences	Remote	0	OPP	HUTUNHAUTRANG!	UnAdk
07 Sep	11:26:28	MM0U1_Amax (BAY-309)	0.045	5.000	LD	stam JOL_NENH_THL	UnAdk	03 Sep	20:33:47	HHTTHT_Subs_CTL_Loc	Local	0.000000	NORMAL	H_TT_NHA_TRANG.:	UnAck RTN
07 Sep	11:26:05	RHCRANH_B11_PPVMax	0.307	5.000	LD	H_CAM_RANH.Subi	UnAck	03 Sep	20:34:15	HHTTHE Subs_CTL Loc	Remote	0	OFF	HUTTUNHAUTRANG.:	UnAdk
								03 Sep	20:34:27	KHITTAT_Subs_CTL_Loc	Local	0.000000	NORMAL	H_TT_NHA_TRANG.:	UnAck RTN
								03 Sep	20:46:05	KHITTHT_Subs_CTL_Loc	Remote	0	OFF	H_TT_NHA_TRANS.	UnAdk
								03 Sep	20:40:17	KHITTNT_Subs_CTL_Loc	Local	0.000000	NORMAL	H_TT_NHA_TRANS.:	UnAck RTN
								00 Sep	20:51:52	KHITTHT_Subs_CTL_Loc	Remote	0	OPP	H_TT_NHA_TRANS.	UnAdk
								03 Sep	20:52:13	KHITNT_Subs_CTL_Loc	Local	0.0000000	NORMAL	H_TT_NHA_TRANG.:	UnAck RTN
Alarm Louol	2							03 Sep 03 Sep	20:52:13	NHTTNT_Subs_CTL_Loc NHTTNT_Subs_CTL_Loc	Local Remote	0.000000	OFF	H_TT_NHA_TRANG.	UnAck RTN UnAck
Alarm Level	3							03 Sep 03 Sep 03 Sep	20:52:13 20:58:20 20:58:32	NHTTHT_Subs_CTL_Lec NHTTHT_Subs_CTL_Lec NHTTHT_Subs_CTL_Lec	Local Remote Local	0.000000	NORMAL OFF NORMAL	H_TT_NHA_TRANS.: H_TT_NHA_TRANS.: H_TT_NHA_TRANS.:	UnAck RTN UnAck UnAck RTN
Alarm Level	3 Tine	Alam Comment	Value	Linit	Type	Group	State	03 Sep 03 Sep 03 Sep 03 Sep	20:52:13 20:58:20 20:58:32 20:59:30	NHTHI Subs_CTL_Loc NHTHI Subs_CTL_Loc NHTHI Subs_CTL_Loc NHTHI Subs_CTL_Loc	Local Remote Local Remote	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	NORMAL OFF NORMAL OFF	H_TT_NHA_TRANG: H_TT_NHA_TRANG: H_TT_NHA_TRANG: H_TT_NHA_TRANG:	UnAck RTN UnAck UnAck RTN UnAck
Alarm Level Date 07 Sep	3 Tine 11:28:06	Alam Connert IN ICRANE (SIL) (SWITT	Value INTERMEDIATE	Link	Type Status	Group JOH_CAM_RANHAD	State A UnAdk	03 Sep 03 Sep 03 Sep 03 Sep 03 Sep	20:52:13 20:58:20 20:58:32 20:59:30 20:59:42	NITTIT_SUB_CT_Loc NITTIT_SUB_CT_Loc NITTIT_SUB_CT_Loc NITTIT_SUB_CT_Loc NITTIT_SUB_CT_Loc	Local Remote Local Remote Local	0 0 0 0 0 0 0 0 0 0 0	NORMAL OFF NORMAL OFF NORMAL	H_TT_NHA_TRANG: H_TT_NHA_TRANG: H_TT_NHA_TRANG: H_TT_NHA_TRANG: H_TT_NHA_TRANG:	UhAck RTN UhAck UhAck RTN UhAck UhAck RTN
Alarm Level Date 07 Sep 07 Sep	3 Tine 11:28:06 11:28:06	AlamConneri HIGRARI (KDL) SWITT HIGRARI (KDL) SWITT2	Value DITERMEDIATE DITERMEDIATE	Link	Type Status Status	Бгокр хн.сам.раен.ко хн.сам.раен.ко	State * UnAdk UnAdk	03 Sep 03 Sep 03 Sep 03 Sep 03 Sep 03 Sep	20:52:13 20:58:20 20:58:32 20:59:30 20:59:42 21:00:24	NITTI Subs_CT_Loc NITTI_Subs_CT_Loc NITTI_Subs_CT_Loc NITTI_Subs_CT_Loc NITTI_Subs_CT_Loc NITTI_Subs_CT_Loc	Local Remote Local Remote Local Remote	0.000000 0 0 0 0.000000 0	NORMAL OFF NORMAL OFF	H_TT_NHA_TRANG: H_TT_NHA_TRANG: H_TT_NHA_TRANG: H_TT_NHA_TRANG: H_TT_NHA_TRANG: H_TT_NHA_TRANG:	UnAck RTN UnAck RTN UnAck RTN UnAck RTN UnAck RTN UnAck
Alarm Level Date 07 Sep 07 Sep 07 Sep	3 Tine 11:28:06 11:28:06 11:28:06	AlamConner/ INGRAM()01)09/111 INGRAM()08)09/172 INGRAM(05)09/172	Value DITERMEDIATE DITERMEDIATE DITERMEDIATE	Linit	Type Status Status Status	Group JALCAN, RANKLOO JALCAN, RANKLOO JALCAN, RANKLOO	State × UnAck UnAck UnAck	0.3 Sep 0.3 Sep 0.3 Sep 0.3 Sep 0.3 Sep 0.3 Sep 0.3 Sep	20:52:13 20:58:20 20:58:32 20:59:30 20:59:42 21:00:24 21:00:24	WITH Star CT, Lee WITH Star CT, Lee	Local Remote Local Remote Local Remote Local	0.000000 0 0.000000 0 0 0.000000	NORMAL OFF NORMAL OFF NORMAL	H_TT_NHA_TRAVS.: H_TT_NHA_TRAVS.: H_TT_NHA_TRAVS.: H_TT_NHA_TRAVS.: H_TT_NHA_TRAVS.: H_TT_NHA_TRAVS.: H_TT_NHA_TRAVS.:	UnAck RTN UnAck RTN UnAck RTN UnAck RTN UnAck RTN UnAck RTN
Alarm Level Date 075ep 075ep 075ep 075ep	3 Tine 11:28:05 11:28:05 11:28:05 11:28:05	Alam Connert 1945249 (1911)59/11 1945249 (1915)59/172 1945249 (1957)59/172	Value DITERMEDIATE DITERMEDIATE DITERMEDIATE DITERMEDIATE	Link	Type Status Status Status Status	Group Joh CAM, RANHLOO Joh CAM, RANHLOO Joh CAM, RANHLOO Joh CAM, RANHLOO	State × Unitak Unitak Unitak Unitak	03 Sep 03 Sep 03 Sep 03 Sep 03 Sep 03 Sep 03 Sep 03 Sep	20:52:13 20:58:20 20:58:32 20:59:42 21:00:24 21:00:24 21:10:17 21:12:14	WHTH SANCTLIC WHTH SANCTLIC WHTH SANCTLIC WHTH SANCTLIC WHTH SANCTLIC WHTH SANCTLIC WHTH SANCTLIC	Local Remote Local Local Remote Local Remote	0.000000 0 0.000000 0 0 0.000000 0 0	NORMAL OFF NORMAL OFF NORMAL OFF	H_TT_MALTRANS: H_TT_MALTRANS: H_TT_MALTRANS: H_TT_MALTRANS: H_TT_MALTRANS: H_TT_MALTRANS: H_TT_MALTRANS:	UnAck RTN UnAck UnAck RTN UnAck UnAck RTN UnAck UnAck RTN UnAck
Alarm Level Date 07 Sep 07 Sep 07 Sep 07 Sep 07 Sep 07 Sep	3 Tine 11:28:05 11:28:05 11:28:05 11:28:05 11:28:05	Alam Connert Increase (inc.) (SW111 Increase (inc.) (SW172 Increase (inc.) (SW172 Increase (inc.) (SW172 Increase (inc.) (SW172)	Vake DITERMEDIATE DITERMEDIATE DITERMEDIATE DITERMEDIATE	Link	Type Status Status Status Status Status	Group Joh CAM, RANHLOO Joh CAM, RANHLOO Joh CAM, RANHLOO Joh CAM, RANHLOO Joh CAM, RANHLOO	State A Unitek Unitek Unitek Unitek Unitek	03 Sep 03 Sep 03 Sep 03 Sep 03 Sep 03 Sep 03 Sep 03 Sep 03 Sep	2015213 20158130 20158132 20159130 20159142 2110324 2110317 2111214 2111214	NITTE SANCTAL SE NITTE SANCTALSE NITTE SANCTALSE NITTE SANCTALSE NITTE SANCTALSE NITTE SANCTALSE NITTE SANCTALSE NITTE SANCTALSE NITTE SANCTALSE	Local Remote Local Remote Local Remote Local	0.000000 0 0.000000 0 0.000000 0 0.000000	NORMAL OFF NORMAL OFF NORMAL OFF NORMAL	н трик, таких: н трик, таких:	UnAck RTN UnAck RTN UnAck RTN UnAck UnAck RTN UnAck RTN UnAck RTN UnAck RTN
Alarm Level Date 075ep 075ep 075ep 075ep 075ep 075ep 075ep 075ep 075ep	3 Tine 11:28:05 11:28:05 11:28:05 11:28:05 11:28:06 11:28:06	AlamConnert INCRAP. (01,200111 INCRAP. (05,200172 INCRAP. (05,200172 INCRAP. (05,200172 INCRAP. (05,20012 INCRAP. (12,20012	Value DITERMEDIATE DITERMEDIATE DITERMEDIATE DITERMEDIATE DITERMEDIATE	Linit	Type Status Status Status Status Status Status	Блор .ют.с.м., клин.кол .ют.с.м., клин.кол .ют.с.м., клин.кол .ют.с.м., клин.кол .ют.с.м., клин.кол .ют.с.м., клин.кол .ют.с.м., клин.кол	State A United United U	0.3 Sep 0.3 Sep 0.3 Sep 0.3 Sep 0.3 Sep 0.3 Sep 0.3 Sep 0.3 Sep 0.3 Sep 0.3 Sep	2015213 20158-20 20158-32 20159-32 20159-42 21100-24 21100-37 2111214 2111214 2111241	NTTTT SANS, CT, Joe NTTTT SANS, CT, Joe	Local Remote Local Remote Local Remote Local Remote Local Remote	0.000000 0 0.000000 0 0.000000 0 0.000000	NORMAL OFF NORMAL OFF NORMAL OFF NORMAL OFF	н ттури, такис: н тури, такис: н тури, такис:	UnAck RTN UnAck RTN UnAck RTN UnAck RTN UnAck RTN UnAck RTN UnAck RTN UnAck RTN UnAck
Alarm Level 07 Sep 07 Sep 07 Sep 07 Sep 07 Sep 07 Sep 07 Sep 07 Sep	3 Tine 11:26:06 11:26:06 11:26:06 11:26:06 11:26:06 11:26:06	Abm Context In CRAINE (201,200/11) IN CRAINE (201,200/12) IN CRAINE (207,200/11) IN CRAINE (207,200/11) IN CRAINE (207,200/11) IN CRAINE (207,200/11) IN CRAINE (11,1) CC, CRAINE	Value DITERMEDIATE DITERMEDIATE DITERMEDIATE DITERMEDIATE DITERMEDIATE Substation	Linit	Type Status Status Status Status Status	Блоср ХОН_САМ, КАМН X00 ХОН_САМ, КАМН X00 ХОН_САМ, КАМН X00 ХОН_САМ, КАМН X00 ХОН_САМ, КАМН X00 ХОН_САМ, КАМН X10 ХОН_САМ, КАМН X10	State Unikk Unikk Unikk Unikk Unikk Unikk	03 Sep 03 Sep	2015213 20158-20 20158-20 20159-30 20159-42 21100.24 21100.24 21112.14 21112.14 21112.41 21116.00 21116.24	8000 (344), (144	Lool Renote Lool Renote Lool Renote Lool Renote Lool Renote Lool	0.000000 0 0.000000 0 0.000000 0.000000 0 0.000000	NORMAL OFF NORMAL OFF NORMAL OFF NORMAL OFF	н ттури, такка: н ттури, такка:	Unikék RTN Unikék Unikék RTN Unikék RTN Unikék Unikék RTN Unikék Unikék RTN Unikék
Alarm Level Date 075ep	3 Tine 11:28:06 11:28:06 11:28:06 11:28:06 11:28:06 11:28:06 11:28:06	Aban Connext PriceAvery (30, 2) with 1 PriceAvery (30, 2) with 2 PriceAvery (30, 2) with 2 PriceAvery (30, 2) with 2 PriceAvery (30, 2) with 2 PriceAvery (31, 2) with 2 Price	Volue DITERNEDIATE DITERNEDIATE DITERNEDIATE DITERNEDIATE DITERNEDIATE Substan DITERNEDIATE	Link	Type Status Status Status Status Status Status Status	Group Joh CAM, RANHUDD Joh CAM, RANHUDD Joh CAM, RANHUDD Joh CAM, RANHUDD Joh CAM, RANHUDD Joh CAM, RANHUDD Joh CAM, RANHUDD	State A Unikak Unikak Unikak Unikak Unikak Unikak	03 Sep 03 Sep	2015213 20158-22 20159-32 20159-30 20159-32 21103-24 21103-24 21112-14 21112-14 21112-14 21112-14 21116-24 21115-40	8 mm (ske, CL) se 9 mm (ske, CL) se	Local Remote Local Remote Local Remote Local Remote Local Remote Local Remote	0.00000 0 0.000000 0 0.000000 0 0.000000	NORMAL OFF NORMAL OFF NORMAL OFF NORMAL OFF NORMAL OFF	н ттуни, такие: н ттуни, такие: н ттуни, такие: н ттуни, такие: н ттуни, такие: н ттуни, такие: н туни, такие: н туни, такие: н туни, такие: н туни, такие: н туни, такие: н туни, такие:	Unide RTN Unide Unide RTN Unide RTN Unide RTN Unide RTN Unide RTN Unide RTN Unide RTN Unide RTN Unide RTN Unide RTN
Alarm Level Date 07 Sep 07 Sep	3 Tine 11:28:06 11:28:06 11:28:06 11:28:06 11:28:06 11:28:06 11:28:06 11:28:06	Alam Connerf INCRANE_03_SW111 INCRANE_03_SW112 INCRANE_05_SW112 INCRANE_05_SW112 INCRANE_05_SW112 INCRANE_15_SW112 INCRANE_05_SW112 INCRANE_05_SW111 INCRANE_05_SW111	Vale DITESMEDIATE DITESMEDIATE DITESMEDIATE DITESMEDIATE DITESMEDIATE DITESMEDIATE DITESMEDIATE DITESMEDIATE	Link	Type Status Status Status Status Status Status Status	Бтоср 30+ САМ, RAVELION 30+ САМ, RAVELION	State Custada Usalada Usalada Usalada Usalada Usalada Usalada Usalada Usalada Usalada	03 Sep 03 Sep	2015213 2015820 2015832 2015930 2015942 2100024 211024 2111214 2111241 2111600 2111624 21116424 2111640	Bitting Sang, Chijao Bitting Sang, Chijao	Local Remote Local Remote Local Remote Local Remote Local Remote Local	0.00000 0.00000 0.00000 0.00000 0.00000 0.00000 0.00000 0.00000 0.00000	NORMAL OFF NORMAL OFF NORMAL OFF NORMAL OFF NORMAL OFF	Н. ТТ. (МА, ТКИВС) Н. ТТ. (МА, ТКИВС)	UNACK RTN UNACK RTN UNACK RTN UNACK RTN UNACK RTN UNACK RTN UNACK RTN UNACK RTN UNACK RTN
Alarm Level Date 07 Sep 07 Sep	3 Tine 11:28:06 11:28:06 11:28:06 11:28:06 11:28:06 11:28:06 11:28:06 11:28:06 11:28:06	Alam Connert 90CANH, gol, Sont11 90CANH, gol, Sont21 90CANH, gol, Sont22 90CANH, gol, Sont21 90CANH, gol, Sont21 90CANH, gol, Sont21 90CANH, gol, Sont21 90CANH, gol, Sont21	Value DITERMEDIATE DITERMEDIATE DITERMEDIATE DITERMEDIATE DITERMEDIATE DITERMEDIATE DITERMEDIATE DITERMEDIATE	Link	Type Status Status Status Status Status Status Status Status Status Status	6000 201 CAM (RANNO) 201 CAM (RANNO)	State Unitek Unitek Unitek Unitek Unitek Unitek Unitek Unitek	00 Sep 00 Sep	2015213 2019620 2019620 2019642 2019942 2019942 2019942 2019942 201924 201024 201924 2		Lool Remote Lool Remote Lool Remote Lool Remote Lool Remote Lool Remote Lool Remote	0.00000 0.000000 0.000000 0.000000 0.000000	NORMAL OFF NORMAL OFF NORMAL OFF NORMAL OFF NORMAL OFF	H.(T.) (M.), TRANS: M.(T.) (M.), TRANS:	Unick RTN Unick Unick RTN Unick RTN Unick Unick RTN Unick Unick RTN Unick Unick RTN Unick Unick RTN Unick Unick RTN Unick
Alarm Level Dote 075ep 0	3 Tine 11:28:06 11:28:06 11:28:06 11:28:06 11:28:06 11:28:06 11:28:06 11:28:06 11:28:06 11:28:06	AlamConnect 9900449,031,304711 9900449,031,30472 9900449,031,30472 9900449,131,30472 9900449,131,30472 9900449,131,30472 9900449,031,30472 9900449,031,30472	Valo DITESMEDIATE DITESMEDIATE DITESMEDIATE DITESMEDIATE DITESMEDIATE DITESMEDIATE DITESMEDIATE DITESMEDIATE	Link	Type Status Status Status Status Status Status Status Status Status Status	6000 201_CM 2004000 201_CM 2004000 201_CM 2004000 201_CM 2004000 201_CM 2004000 201_CM 2004000 201_CM 2004000 201_CM 2004000 201_CM 2004000 201_CM 2004000	Sible Cubick Unick Unick Unick Unick Unick Unick Unick Unick Unick Unick	00 Sep 00 Sep	3052013 20198020 20198020 20198020 20198020 20198020 20198020 20198020 20198020 20198020 20198020 2019800 2019800 2019800 2019800 2019800 2019800 20198020 2019800 20000000000000000000000000000000000	Bitting Sang, Chujae Bitting Sang, Chujae	Local Remote Local Remote Local Remote Local Remote Local Remote Local Remote Local Remote Local	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	NORMAL OFF NORMAL OFF NORMAL OFF NORMAL OFF NORMAL OFF NORMAL	(1), 1), 44, 13, 46, 45 (1), 12, 94, 13, 46, 45 (1), 12, 94, 13, 46, 45 (1), 13, 94, 13, 46 (1), 144, 134, 146 (1), 144, 146 (1), 146, 146 (1)	Unick RTN Unick Unick RTN Unick RTN Unick RTN Unick RTN Unick RTN Unick RTN Unick RTN Unick RTN Unick RTN
Alarm Level Date O Sep	3 Tree 11:28:06 11:28:06 11:28:06 11:28:06 11:28:06 11:28:06 11:28:06 11:28:06 11:28:06 11:28:06	Abst.Conset #CGAM4_GBWTT1 #CGAM4_GBWTT2 #CGAM4_GB_	Vale DITERMEDIATE DITERMEDIATE DITERMEDIATE DITERMEDIATE DITERMEDIATE DITERMEDIATE DITERMEDIATE DITERMEDIATE DITERMEDIATE DITERMEDIATE	Link	Type Status Status Status Status Status Status Status Status Status Status Status Status	6000 201_204(200430) 201_204(200430) 201_204(2004400) 201_204(2004400) 201_204(2004400) 201_204(2004400) 201_204(2004400) 201_204(2004400)	State A Unick Unick Unic	00 Sep 00	3055213 20158-22 20159-22 20159-22 2110024 2110024 2110027 2111214 2111214 2111214 2111214 2111600 2111604 21119-00 2111604 21119-00 2111024 21119-00 2111024 21119-00 2111024 21119-00 2111024 21119-00 2111024 21119-00 2111024 21119-00 2111024 21119-00 2111024 21119-00 2111024 21119-00 2000-00 20000-00 2000-0000-00000000	Brith San, Chuke Brith San, Chuke	Lood Renote Lood Renote Lood Renote Lood Renote Lood Renote Lood Renote Lood Renote Lood Renote Lood Renote	0.00000 0 0.000000 0 0.000000 0 0.000000	NORMAL OFF NORMAL OFF NORMAL OFF NORMAL OFF NORMAL OFF NORMAL OFF	(1) Τ. Μ. (TANG): (1) Τ. (M. (TANG): (1) T. (M	UNACK RTN UNACK
Alarm Level Date 07 Sep 07 Sep	3 Tree 11:28:05 11:28:05 11:28:05 11:28:05 11:28:05 11:28:05 11:28:05 11:28:05 11:28:05 11:28:05 11:28:05 11:28:05	Alam.Connect 9600449, (2012, 20011) 9600449 (2012, 20012) 9600449 (2012, 20012) 9600449 (2012, 20012) 9600444 (2012, 20012) 9600444 (2012, 20012) 9600444 (2012, 20012) 9600444 (2012, 20012) 9600444 (2012, 20012)	Value DITERMEDIATE DITERMEDIATE DITERMEDIATE DITERMEDIATE DITERMEDIATE DITERMEDIATE DITERMEDIATE DITERMEDIATE DITERMEDIATE DITERMEDIATE	Link	Type Status Status Status Status Status Status Status Status Status Status Status Status	6000 201 (204) RANN 20 201 (204) RANN 20	State a Unitek Unitek Unitek Unitek Unitek Unitek Unitek Unitek Unitek Unitek Unitek	00 Sep 00	3052013 20198-32 20198-32 20198-32 20198-32 20198-42 21000-44 21000-44 21000-44 21016-04 21016-04 21016-04 21016-04 21016-04 21016-04 21016-04 21016-04 21016-04 21010-05 0016-05 001130-6 001130-6		Lood Rente Lood Lood Lood Rente Lood Rente Lood Rente Lood Rente Lood Rente Lood	C.000000 0 C.000000 0 C.000000 0 C.000000 0 C.000000 0 C.000000 0 C.000000 0 C.000000 0 C.000000 0 C.000000	NORMAL OFF NORMAL OFF NORMAL OFF NORMAL OFF NORMAL OFF NORMAL	(1) Τ. Μ. (TANG): (1) Τ. (M. (TANG): (1) T. (M	Undek RTN Undek RTN
Alarm Level Date 07 Sep 07	3 Tine 11:28:00 11:28:00 11:28:00 11:28:00 11:28:00 11:28:00 11:28:00 11:28:00 11:28:00 11:28:00 11:28:00 11:28:00 11:28:00	Alter-Connect In-County (cd.), 20011 In-County (cd.), 200172 In-County (cd.), 200172 In-County (cd.), 20012 In-County (cd.), 20012 In-County (cd.), 20012 In-County (cd.), 20012 In-County (cd.), 20012 In-County (cd.), 20011 In-County (cd.), 20011 In-County (cd.), 20011 In-County (cd.), 20011 In-County (cd.), 20011 In-County (cd.), 20011	Value INTERMEDIATE INTERMEDIATE INTERMEDIATE INTERMEDIATE INTERMEDIATE INTERMEDIATE INTERMEDIATE INTERMEDIATE INTERMEDIATE INTERMEDIATE	Link	Type Status Status Status Status Status Status Status Status Status Status Status Status Status Status	501 CAM (RAN-130) API CAM (RAN-130)	State A Unida: Unida: Unida: Unida: Unida: Unida: Unida: Unida: Unida: Unida: Unida: Unida: Unida: Unida:	00 Sep 00	3055213 20158-22 20159-30 20159-30 20159-42 2110024 2110037 2111214 21115-00 21110-42 21115-00 2110025 0006615 0019-05 00114-05 00114-05		Lisod Renote Lisod Renote Lisod Renote Lisod Renote Lisod Renote Lisod Renote Lisod Renote Lisod Renote Lisod Renote Lisod	C.00000 C.000000 C.000000 C.000000 C.000000 C.000000 C.000000 C.000000 C.000000 C.000000 C.000000 C.000000 C.000000 C.0000000 C.0000000 C.0000000 C.0000000 C.0000000 C.0000000 C.0000000 C.0000000 C.0000000 C.0000000 C.0000000 C.0000000 C.0000000 C.0000000 C.0000000 C.0000000 C.0000000 C.0000000 C.0000000 C.0000000 C.0000000000	NORMAL OFF NORMAL OFF NORMAL OFF NORMAL OFF NORMAL OFF NORMAL OFF NORMAL OFF	(1) Τ. Μαζ, ΤΑΝΟΣ, (1) Τ. JANG, (2) Τ. J	Unack RTN Unack RTN RTN RTN RTN RTN RTN RTN RTN RTN RTN
Alarm Level Dia 07 Sep 07 Sep	3 Tine 11:28:06 11:28:06 11:28:06 11:28:06 11:28:06 11:28:06 11:28:06 11:28:06 11:28:06 11:28:06 11:28:06	Nan Conset 9-Class (3), 20071 9-Class (3), 20072 9-Class (3), 20072 9-Class (3), 20072 9-Class (3), 20071	Value INTERNEDIATE INTERNEDIATE INTERNEDIATE INTERNEDIATE INTERNEDIATE INTERNEDIATE INTERNEDIATE INTERNEDIATE INTERNEDIATE INTERNEDIATE INTERNEDIATE INTERNEDIATE INTERNEDIATE	Lint	Type Status Status Status Status Status Status Status Status Status Status Status Status Status Status Status	Group An _ Cark _ Rakeston	State Undek	0 3 Sep 0 5	365513 20158-22 20159-22 20159-22 20159-42 20059-20 20159-42 20057 20112-44 20112-44 20115-40 20112-44 20115-40 20112-45 0006-15 00112-45 00112-45 00112-45	emm (Jac, 1), as emm (Jac, 1)	Lood Renote Lood Renote Lood Renote Lood Renote Lood Renote Lood Renote Lood Renote Lood Renote Lood	0.00000 0 0.000000 0 0.000000 0 0.000000	NORMAL OFF NORMAL OFF NORMAL OFF NORMAL OFF NORMAL OFF NORMAL OFF NORMAL OFF NORMAL OFF	(1) Τ. Μαζ, ΤΑΝΟΣ (Τ. Τ.) Μαζ, ΤΑΝΟΣ	Undek RTN Undek Undek RTN Undek RTN
Alarm Level Date 07 Sep 07 Sep	3 Tite 11.28.05 11.28.0	Abst.Conset 900,049 (30),0007 900,049 (30),0007	Value Intermediate Intermediate Intermediate Intermediate Intermediate Intermediate Intermediate Intermediate Intermediate Intermediate Intermediate Intermediate Intermediate Intermediate Intermediate	Lint	Type Status Stat	61040 241 (244 (2444-02) 241 (244 (244 (244)) 241 (244 (244)) 241 (244 (244))	State A Undek Undek Undek Undek Undek Undek Undek Undek Undek Undek Undek Undek Undek Undek Undek Undek	0 3 Sep 0 5	3055213 20158-20 20158-22 20159-30 20159-30 20159-30 20159-32 21102-44 21105-24 21115-24 2115	emm (Jac, CL) is emm (J	Licol Revolte Revolte Licol Re	0.00000 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	NORMAL OFF NORMAL OFF NORMAL OFF NORMAL OFF NORMAL OFF NORMAL OFF NORMAL OFF	(1), 1), 40, 13, 40, 23, 40, 24, 40, 25, 40, 2	UNACK RTN UNACK UNACK RTN UNACK RTN RTN RTN RTN RTN RTN RTN RTN RTN RTN
Alarm Level 0749 0749 0749 0749 0749 0749 0749 0749	3 Title 11:28:05 11:28:	Absr.Conect 900,049 (30,0007) 900,049 (30,0077) 900,049 (30,0077) 900,049 (30,0077) 900,049 (30,007) 900,049 (30,007)	Value Intervecture Intervecture Intervecture Intervecture Intervecture Intervecture Intervecture Intervecture Intervecture Intervecture Intervecture Intervecture Intervecture Intervecture Intervecture Intervecture Intervecture	Lint	Tipe Status	6000 341_044_04400 341_044_04400 341_044_04400 341_044_04400 341_044_04400 341_044_044400 341_044_044400 341_044_044400 341_044_044400 341_044_0444400 341_044_0444400 341_044_0444400 341_044_0444400 341_044_0444400 341_044_0444400 341_044_0444400 341_044_0444400 341_044_0444400 341_044_044400 341_044_044400 341_044_044400 341_044_044400 341_044_044400 341_044_044400 341_044_044400 341_044_044400 341_044_04400 341_04400 341_04400 341_04400 341_04400 341_04400 341_04400 341_04000 341_0400 341_0400 341_0400 341_0400 341_0400 341_0400 341_0400 341_0400 341_0400 341_0400 341_0400 341_0400 341_0400 341_0400 341_04000 341_04000 341_04000 341_040000 341_040000 341_040000 341_040000000000000000000000000000000000	State United Un	0 3 Sep 0 4 Sep 0 4 Sep 0 4 Sep 0 4 Sep 0 5	365513 20158-22 20159	emm jake july as memory and july as memory as	Lisod Remote Lisod Remote Lisod Remote Lisod Remote Lisod Remote Lisod Remote Lisod Remote Lisod Remote Lisod Remote Lisod Remote Lisod Remote Lisod	0.00000 0 0.000000 0 0.000000 0 0.000000	NORMAL OFF NORMAL OFF NORMAL OFF NORMAL OFF NORMAL OFF NORMAL OFF NORMAL OFF NORMAL OFF	(1) TUMU, TANGE (1) TUMU, TUMU, TUMU, TUMU, TUMU, TUMU, TUMU, TUMU, TUMU,	UNACK RTN UNACK RTN
Alarm Level 5.544 5.545 5.54	3 Tre 11:28:06 11:28:08 11:28:08 11:28:08 11:28:08 11:28:08 11:28:08 11:28:08 11:28:08 11:28:	AlsoConst 9000447,01,00011 9000447,01,00011 9000447,01,00011 9000447,01,00011 9000447,01,00011 9000447,01,00011 9000447,01,00011 9000447,01,00011 9000447,01,00011 9000447,01,00011 9000447,01,00011 9000447,01,00011 9000447,01,00011 9000447,01,00011 9000447,01,00011 9000447,01,00011 9000447,01,00011 9000447,01,00011 9000447,01,00011 9000447,01,00011 9000447,01,00011 9000447,01,00011 9000447,01,00011	Valac PICESMELATE PICESMELATE PICESMELATE PICESMELATE PICESMELATE PICESMELATE PICESMELATE PICESMELATE PICESMELATE PICESMELATE PICESMELATE PICESMELATE PICESMELATE PICESMELATE PICESMELATE	Lint	Type Status Stat	61000 217 (204 (2044)20 217 (204 (204 (2044)20 217 (204 (204 (2044)20 217 (204 (204 (2044)20 217 (204 (204 (204 (204 (204 (204 (204 (204	State Control of Contr	0 3 Sep 0 5	3055213 201580-2 201580-2 201590-2 21009542 2100037 2111214 2111241 2111241 2111241 2111540 2111604 2111644 2111241 2111540 2111644 2112042 2110045 2110045 2110045 2100045 200045 2100045 20000000000	emm jake njake emm jake njake njake emm jake njake emm jake njake emm jake njake emm jake njake emm jake njake emm jake njake njake emm jake njake njake emm jake njake njake emm jake njake njake njake emm jake njake njake emm jake njake njake njake emm jake njake njake njake njake emm jake njake njake njake njake njake njake njake njake emm jake njake nja	Lisofi Rente Lisof	0.00000 0 0.000000 0 0.000000 0 0.000000	NORMAL OFF NORMAL OFF NORMAL OFF NORMAL OFF NORMAL OFF NORMAL OFF NORMAL OFF NORMAL OFF NORMAL OFF NORMAL OFF	(1) Τ. Μαζ, ΤΑΚΟΣ, (1) Τ. Μ	Under Thi Under Thi
Alarm Level Due 07 5ep 07 5	3 Toe 11/28/06 11/28/06 11/28/06 11/28/06 11/28/06 11/28/06 11/28/06 11/28/06 11/28/06 11/28/06 11/28/06 11/28/06 11/28/06 11/28/06 11/28/06	AlarConnet 0422447_(21,50011) 0423447_(21,50012)	Valo INTERVENTI	Link	Tool Status	Колор (2004) (2004-000)	State • United •	0 3 See 0 3 Se	3015013 2015802 2015802 2015902 2015902 2015902 2100024 2100024 2110024 2111241 211500 2115024 211502 21150	emm jake til som	Lisoi Rente Lisoi Rente Lisoi Rente Lisoi Rente Lisoi Rente Lisoi Rente Lisoi Rente Lisoi Rente Lisoi Rente Lisoi Rente Lisoi Rente Lisoi Rente	0.00000 0 0.000000 0 0.000000 0 0.000000	NOBMAL OFF NOBMAL OFF NOBMAL OFF NOBMAL OFF NOBMAL OFF NOBMAL OFF NOBMAL OFF	1, 177, 1944, 778,402 177, 1944, 778,402 1, 177, 1944, 778,402 1,	Under Thi Under Thi



γp	No.	Device	Operator	Time	Date	Comments
•	109	132	MAIN	14:53:30	02/05/05	CAM THAO TAC KHI CHUA CO LENH
•	110	443	MAIN	14:54:03	02/05/05	CAM THAO TAC KHI CHUA CO LENH
•	111	136	MAIN	14:54:53	02/05/05	CAM THAO TAC KHI CHUA CO LENH
•	112	151	MAIN	14:55:30	02/05/05	CAM THAO TAC KHI CHUA CO LENH
•	113	152	MAIN	14:56:00	02/05/05	CAM THAO TAC KHI CHUA CO LENH
•	114	175	MAIN	14:56:36	02/05/05	CAM THAO TAC KHI CHUA CO LENH
•		175-7	MAIN	14:56:44	02/05/05	Clear tag 22
•	115	174	MAIN	14:57:15	02/05/05	CAM THAO TAC KHI CHUA CO LENH
•		174-7	MAIN	14:57:24	02/05/05	Clear tag 29
•	116	135	MAIN	14:57:56	02/05/05	CAM THAO TAC KHI CHUA CO LENH
•	117	177	MAIN	14:58:35	02/05/05	CAM THAO TAC KHI CHUA CO LENH
•		177-1	MAIN	14:58:43	02/05/05	Clear tag 91
•	118	173	MAIN	14:59:29	02/05/05	CAM THAO TAC KHI CHUA CO LENH
•		173-7	MAIN	14:59:37	02/05/05	Clear tag 40
•	119	172	MAIN	15:00:22	02/05/05	CAM THAO TAC KHI CHUA CO LENH
•		172-7	MAIN	15:00:29	02/05/05	Clear tag 63
•		171-1	MAIN	15:01:16	02/05/05	Clear tag 45
•		176-1	MAIN	15:01:48	02/05/05	Clear tag 12
•	120	131	MAIN	15:02:24	02/05/05	CAM DONG DIEN KHI CHUA CO LENH
•		131-3	MAIN	15:02:32	02/05/05	Clear tag 60

Figure 20. Trending window

Figure 21. Equipment tagging window

4.4.6. Solar generation forecast

Accurate solar generation forecast is one of the key tools to mitigate challenges created by intermittent nature of energy generation from Renewable Energy systems.

We offer Renewable Energy Generation Forecasting Software for hourahead, day-ahead, week-ahead for individual PV power plants or distributed solar power systems.

We deliver power forecasts for several levels:

- Single solar parks ٠
- Areas
- Countries

We provide AI-powered SaaS Solutions. Our Solution offers features as:

- Hour-ahead forecasting
- day-ahead forecasting ٠
- Week-ahead forecasting ٠
- Custom modeling and development
- **Highest Accuracy** ٠
- Uncertainty bands ٠
- Support multiple format types as xml, csv, sql or support multiple data sources included but not limit to mysql, cloud sql, bigquery, and more.
- SCADA Interfaces

Our System includes two key components:

- Offline Training:
 - Use multiple ML/AI models for PV power dynamics modeling and Pattern Discovery method.
 - Methods used include artificial neural networks, regression models, autoregressive models, support vector machines, and Markov chains, as well as composite methods, such as using genetic algorithms to optimize a neural network.
- Online Forecasting:
 - Use temperature, solar irradiance and history measured PV power with ML/AI model to forecast PV power at time (t + k)

4.4.7. Fault diagnosis

Fault diagnostic function is the integrated solution in @IRIS system for managing the operation of renewable energy plants. It provides services to accurately identify failure situations of devices during real-time operation. The system is designed to comply with IEC61724 standard to ensure smooth operation of PV arrays and optimize power production.

The application will continuously monitor the operation of PV array to detect operation points below the design threshold. It provides data collection in real time as well as the statistics needed to report system status to the operator via computer system, email, browser or SMS.



Figure 22. Solar generation forecast engine

Overall PV Performance







Inverter Performance

Figure 23. Continuously monitor the plant operation



Figure 24. Fault diagnosis

Head Office

Suite #604 - VNA8 Building, 8 Tran Hung Dao Str., Hanoi, Vietnam T. +84-24-3825 1072 F. +84-24-3825 8037 W. www.ats.com.vn E. ecommerce@ats.com.vn

Factory

Lot No. A2CN6, Tu Liem Industrial Zone, Hanoi, Vietnam T. +84-24-3780 5053 F. +84-24-3780 5060

HCMC Office

13-15 Nguyen The Loc Street Ho Chi Minh City, Vietnam T. +84-28-3948 3548 F. +84-28-3948 3549

